Town Hall \* Po Box 150 \* 1019 Main St. \* Branford, CT 06405 CE 203-315-0675 \* FAX 203-889-3172 \* inlandwetlands@branford-likey Spanning Minutes-Approved

Marting Minutes-Approved

Canoe Brook Senior Center, 11 Cherry Hill Rd., Branford, Wednesday, February 22, 2017 5:30 PM

Present: Peter Bassermann, Suzanne Botta, Sandra Kraus, and Eric Rose

Absent: John Rusatsky, Richard Greenalch, James Sette, Jim Goggin, Merle Berke-Schlessel,

Rick Ross

Staff Present: Enforcement Officer Diana Ross

Chairman Bassermann called the meeting to order at 5:35. All present were seated

IW#16.08.01 – Laurel Hill Rd./Piscitello Dr./Queach Rd.- Installation of new water main, approved September 8, 2016

## For Consideration - plan revision for additional work - replacement of culvert at stream crossing

EO Ross presented Sheet 13A, Culvert Replacement plan dated December 2016, to the commission, which depicts the proposed replacement of the culvert pipe located at the stream crossing on the unimproved section of Queach Road. This is required because the contractor found that the bottom of the pipe was rotted out so it needed to be replaced before the water main could be installed underneath it.

The commission reviewed the plan and accepted the revision with two stipulations.

- 1. The water diversion pathway is to be covered with erosion control fabric or something similar that would protect it from erosion from the water flow.
- 2. Upon completion all disturbed soils are to be seeded and stabilized.

Meeting was adjourned at 5:45 by motion of Commissioner Rose and 2<sup>nd</sup> by Commissioner Botta

Respectfully Submitted,

Diana Ross, IWEO