

Town of Branford
Stony Creek Firehouse Parking Lot Restoration
Addendum #2

Date: September 13th, 2022

Submission Date: September 16th, 2022

Prospective bidders, and all those concerned, are hereby informed that the following is made a part of the bid documents, which should be amended as follows:

The following question was received about the bid, with answers following:

Should the item HMA S0.5 in the Bid Proposal Sheet replace the HMA S1 and HMA S0.375 items in the Scope of Work description?

Yes, a unit price shall only be given to the item HMA S0.5. Review the corrected scope of work descriptions below.

Replace the second paragraph of page 13 of the Invitation to Bid with the following:

“The furnishing and placing of bituminous concrete will be paid for at the contract unit price per ton of HMA S0.5. All costs associated with providing illumination of the work area are included in the general cost of the work. All costs associated with cleaning the surface to be paved, including mechanical sweeping, are included in the general cost of the work.”

Replace the fifth paragraph of page 13 of the Invitation to Bid with the following:

“Bituminous Concrete (HMA) – work under this section shall include the production, delivery, placement and compaction of a uniform textured, non-segregated, smooth bituminous concrete pavement to the grade and cross section shown on the plans. Asphalt shall be placed in a 3” lift.”

Respectfully submitted,

Kevin Ortiz, EIT
Civil Design Engineer

Please acknowledge receipt of addendum below and submit with your bid submittal.

Signature: _____ **Date:** _____

Title: _____

Company: _____